

GOVERNMENT OF JAMMU AND KASHMIR
OFFICE OF THE JOINT DIRECTOR FIRE & EMERGENCY SERVICES,
KASHMIR RANGE SRINAGAR

The Principal,
Ladakh Public School,
Leh.

No: JDK/F-Prv/1587

Dated. 19: 4 : 2019.

Subject: - NOC.

Refnce:- This office letter No. JDK/F-Prv/1752-54 Dated 07-03-2019.

Sir,

In continuation to above referred letter, the provisional NOC for Ladakh Public School the school existing in four structures (Three storyed two buildings & Two storyed two buildings) situated at Leh is valid for one year is hereby issued in view:-

(Block A) (Three storyed)

1. Exit. 100 Cm. (02 units) in each building.
2. Corridor. 120 Cm.
3. Fire Extinguishers 02 No's in each floor.


(Block B) (Two storyed)

1. Exit. 100 Cm (two units)
2. Corridor. 110 Cm.
3. Fire Extinguishers 02 No's in each floor.

However the case for final NOC shall be considered subject to having following provisions strictly as per NBC/BIS norms & specifications for both building.

- a) Hose reel at each floor with overhead tank having 10,000 liters & fire pump shall be installed in each building.
- b) Fire Retardant Paint. - Wooden components of the structures especially in attic portion shall be given fire retardant treatment of at least two hours rating.
- c) Precautions:-
 - i. All escape routes shall be kept free from any obstructions to provide hindrance free escape in case of emergency besides all doors, gates shall be kept unlocked during the occupancy of the school building.
 - ii. Class/Halls have a capacity of more than 45 students shall have two exits.
 - iii. Attic portion of the building shall not be used for any kind of storage.
 - iv. Grill fitted in the windows shall be removed.
 - v. Fire/Evacuation drill should be conducted regularly.
 - vi. Employees of the school shall be trained for maintenance & use of Fire Fighting facilities.

Yours faithfully


Joint Director,
Fire & Emergency Services, J&K
Kashmir Range Sgr.