



THE ADMINISTRATION OF UNION TERRITORY OF LADAKH

OFFICE OF THE DIRECTOR FIRE AND EMERGENCY SERVICES UT LADAKH

(e-mail-igp-ladakh@police.ladakh.gov.in)

(Office Phone No: 01982-260888)

No: F&ES/ Dir/NOC/2023-5483-84

Dated: 23/03/2023

Subject: Fire NOC of Ladakh Public School skara, Leh.

The report has been submitted by Superintendent of Police, Fire and Emergency Services, Ladakh regarding the inspection of the School which has been done by DFO Fire and Emergency Services, Leh. The detailed report is as under:

Location/ Accessibility:

The School building is constructed at Skara, Leh. It is located at Longitude 77.574650 and Latitude 34.152406. The site is approximately 03 Kms from Fire and Emergency Services Station, Leh. It takes approximately 6 minutes to reach the site and is approachable for fire appliances.

Detail of building:

The School building has eight blocks. The detail of the block is as under:

1st block: It is two storied building having two staircase. In the ground floor there are 5 number of class rooms. One window in each class room and the size is 4x5 feet. Two side of the windows have provision to open. 1st floor have Principal office, stationery printing and staff room.

2nd block: It is two storied building having two staircase. In the ground floor there are music room and MI room. One window in each room and the size is 3x5 feet. 1st floor have two class rooms.

3rd block: It is two storied building having two staircase. In the ground floor there are three class rooms and one office. There are two windows in each room and the size is 5x5 feet. 1st floor have store room and three class rooms.

4th block: It is three storied building having two staircase. In the ground floor there are five class rooms. There are two windows in each class rooms and the size is 5x10 feet. 1st floor have five class rooms. 2nd floor have library, computer room and math lab.

5th block: It is three storied building having two staircase. In the ground floor there are three class rooms. There are three windows in each class rooms and the size is 5x10 feet. 1st floor have three class rooms. 2nd floor have Physic lab, chemistry lab and bio lab.

6th block: It is single storied building having kitchen and dining hall. Kitchen have one window and the size is 4x6 feet. Dining hall have two windows and the size is 4x6 feet.

7th block: It is single storied multipurpose hall. There are thirteen windows and four exits doors. The size of the window is 5x6 feet.

8th block: It is three storied building having two staircase. In the ground floor there are activity room. The size of the room is 50x20 sq. Feet. There are five windows and two exits doors. The size of the window is 5x10 feet. 1st floor and 2nd floor have two class rooms in each floor.

There are 1120 students and 85 staff in the school.

The following Fire Safety equipment's which are installed in School Building:

01. 20 no's of fire extinguisher ABC Type 4 kg capacity is installed in the school building.
02. 02 no's of submersible bore in the premises of the school building.
03. 04 no's of sand bucket is installed in the school premises.
04. 10 thousand liters underground reserve water tank is installed in the School premises.
05. 05 number of overhead tank 1000 liters capacity.

FIRE NOC is given in favour of Ladakh Public School Skara, Leh for period of One year from the issuance.


Director, F&ES, Ladakh
PHQ, Agaling, Leh

Copy to:

01. Principal, Ladakh Public School Skara, Leh for information and n/a.
02. Superintendent of Police, F&ES, Ladakh for information.
03. Office file.