

OFFICE OF THE INCHARGE FIRE AND EMERGENCY SERVICE STATION LEH-LADAKH

The Principal,
Ladakh Public School,
Leh.

No: F/ES Stn Leh 79

Dated: 17-10-2016

Subject: NOC

Reference: Your application no. nil dated 14-10-2016

Sir,

Please refer to your letter no quoted above. Where in you have requested to this office for issuance of N.O.C in favour of Ladakh Public School. The under signed made spot inspection of school building. You have implemented fire safety measure in your school.

Precaution:-

1. All escape routes shall be kept free from any obstruction to provide hindrance free escape in case of emergency besides all doors. Gate shall be kept unlocked during the occupancy of the school building
2. Class/ Halls have a capacity of more than 45 students shall have two exits.
3. Attic portion of building shall not be used for any kind of storage.
4. Fire/ Evacuation drill should be conducted regularly.
5. Employees of the school shall be trained for maintenance and use of fire fighting facilities.

As such this department has no objection running the building for school.

Your faith fully

In charge
Fire and emergency Service
Station Leh
J&K Fire & Emergency Service
Station Leh - Ladakh